
# Modicon
# 140 DAO 840 10
# 24 ... 115 VAC Output Module

Publication # 043511658

| | |
|---|---|
| **Topology** | 16 isolated output points |
| **Bus Current Required** | 350 mA |
| **Connector** | Modicon P/N 140 XTS 002 00 |




**CAUTION: Each output point must be fused with an external fuse. The recommended fuse is a 5 A fuse (Part # 043502405) or any other fuse with an $I^2T$ rating of less than 87.**

**NOTE 1:** This module is not polarity sensitive.

**NOTE 2:** N / C = Not Connected

For complete information concerning this and other modules, please obtain a copy of the *Quantum Automation Series Hardware Reference Guide* (840 USE 100 00) from your distributor or local sales office.

Quantum Automation Series equipment is protected by U.S. Patent number 5,302,136, and by European Patent number 93202982.0-.

* 4 3 5 1 1 6 5 8 7 7 *

Printed in